

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-1574:114 Page 1 of 1

CATEGORY: Annunciators

LISTEE: ADT Secutity Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ 07004
Contact: *Ron Dalton (310) 725-2972 Fax (310) 725-2942

DESIGN: Models QSA-1-S, QSA-1-F, QSA-2-S, QSA-2-F remote annunciator cabinets; followed by -1 or -2, followed by -S or -F stands for 1 or 2 zone, Surface or Flush mount and includes Model RAI remote annunciator interface. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Model designation, model number, electrical rating and UL label.

APPROVAL: Listed as remote annunciator for use with listee's separately listed Models ADTQSC, -ADTQS1 and -ADTQS4 (CSFM Listing No. 7165-1574:115*) fire alarm control units. Refer to manufacturer's Installation Manual for details.

XLF: 7120-1591:206 Formerly 7120-1388:236

*Rev. 06-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 2, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager